

TRANSPORTATION DEPARTMENT

TRAFFIC ENGINEERING DIVISION

Residential driveway apron access;

The approval of this driveway apron permit was based on information that was provided by the contractor, developer and/or homeowner. The contractor, developer and/or homeowner are responsible to ensure that the driveway apron(s) are constructed according to all current City of Asheville guidelines, specifications and standards.

The approval of this driveway apron permit does not imply or guarantee that the driveway apron(s) can be constructed because of existing topography and/or other challenges.

Driveway aprons that serve single-family units must be built in accordance with one of the following designs.

1. 6 inches of 4000 PSI concrete on 6 inches 100% compacted CABC stone.
2. 2 inches of Type II asphalt on 6 inches 100% compacted CABC stone.

The driveway apron must extend a minimum of 10 feet from the roadway pavement edge. If a sidewalk exists, the driveway apron must extend another 10 feet past the sidewalk (this 10 foot section may be either concrete or asphalt).

The driveway apron radii must be 3 feet 6 inches (42 inches).

The grade in the first 10 feet of the driveway apron must be in the range of -4% to +10.6%.

If removal of trees is required in the right-of-way for placement of the driveway apron opening, please contact Mark Foster @ 259-5979.