

Asheville Fire Department - FMO  
P.O. Box 7148  
Asheville, NC 28802  
(828) 259-5640



Tuesday, 19 October, 2021

Attn: RAY GRIFFITHS  
50 S FRENCH BROAD AVE 246  
ASHEVILLE, NC 28801

Property Address:  
Sunrise Community for Recovery & Wellness  
50 S FRENCH BROAD AVE 242  
ASHEVILLE, NC 28801

Re: Initial - Mandatory on October 19 2021

**EXPLANATION OF PERIODIC FIRE INSPECTION REPORT AND YOUR RESPONSIBILITIES AS  
PROPERTY MANAGER, BUSINESS OWNER OR DESIGNATED REPRESENTATIVE**

**ORDER TO COMPLY:** As a result of an inspection of the premises listed below, there are some violations that have been identified for correction. Failure to correct noted violations on this report will result in the doubling of your inspection fee every 14 days until corrections are complete. In addition, maintaining these violations can result in civil penalties. If you need assistance or additional time, you may contact the Fire Code Official listed in the report.

You will be receiving an invoice from the City of Asheville within the next 30 days for this fire inspection which will include the fee for this inspection and an additional 5% technology fee.

City Ordinances and NC General Statutes charge the Fire Code Official with the responsibility of protecting the people and properties from the ravages of fire. This is accomplished by an organized program of inspections, and enforcement of Codes, Statutes, and Standards intended to minimize the community's fire loss. If there are any questions or needs for assistance with the correction of the violations, don't hesitate to contact the Asheville Fire Department Fire Marshal Office at 828-259-5640 or email [AFDFMO@Ashevillenc.gov](mailto:AFDFMO@Ashevillenc.gov)

# Asheville Fire has partnered with Fire Recovery USA!

Dear business owner,

We would like to make you aware of billing changes to periodic fire inspections.

The City of Asheville has contracted with Fire Recovery USA, LLC, a 3rd party billing service, to administer billing on behalf of the Asheville Fire Department.

You will receive a bill from Fire Recovery USA, LLC with an Atlanta, GA return address. Additionally, you may receive phone calls from Fire Recovery USA, LLC based in California.

For questions regarding billing please call 888-650-5320.



Inspector:

A handwritten signature in black ink, appearing to read "AMCKINNEY", written over a horizontal line.

FFS ANDREW MCKINNEY

amckinney@ashevillenc.gov

828-620-1838

Property Representative:

A handwritten signature in black ink, appearing to read "RAY GRIFFITHS", written over a horizontal line.

RAY GRIFFITHS

**Violation/Information Page(s)**

General Inspection Information

Inspection Fee plus 5% Technology Fee

Inspection Violations

**Extension cords are not being used in lieu of permanent wiring.**

**605.5** "Extension cords and flexible cords shall not be a substitute for permanent wiring. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances."

**Inspector Notes: DISCONTINUE USE OF EXTENSION CORD.**

Violation found on  
10/19/2021

Will be rechecked on or after  
11/08/2021

Violation Not  
Repaired

Manage Violation using Self-Certification Website (Use Link Below)

<https://www.theregistrationhub.com//NC01101/Home/Default?l=t&RegistrationID=6458556>

